

TEST REPORT**395699 / 1**Revision: 0
Date of sample receipt: 07/07/25
Date of test: 23/07/25
Date of issue: 23/07/25
Sample name: FLEX PAINTKERAKOLL S.P.A.
VIA DELL'ARTIGIANATO 9
41049 SASSUOLO (MO)
ITALIA**Determination of Metals CAM - PTP 174 Rev. 2 del 2020****OBJECTIVE**

Determinations of dangerous substances in material
to point 2.5 of the CAM (Minimum Environmental Criteria)
for awarding the design and execution of construction work

MATERIAL

Paints and coatings (2.5.13)

SAMPLE PREPARATION

The material has been digested with acid mixture

USED TECHNIQUE

ICP-OES: Inductively Coupled Plasma - Optical Emission Spectroscopy

UV-VIS: Ultraviolet Visible Emission Spectroscopy

TEST RESULTS

The result is expressed on the dried sample

ANALYZED METALS	VALUE mg/kg	Note
As	< 10	< 100 (*)
Cd	< 10	
Cr (VI)	< 10	
Hg	< 10	
Pb	< 10	
Se	< 10	

(*)The material complies with point b of paragraph 2.5.13 Minimum Environmental Criteria (CAM)
referred to the Ministerial Decree dated 23/06/2022 n. 256 G.U. n. 183 dated 6/08/2022 - effective from 4/12/2022

This test report is part of a PDF file digitally signed by Paolo Tirelli.

The managing director
Dr. Paolo Tirelli

Chemical Testing Manager
Dr. Daniele Bergamasco
Chemist
Association of Chemists and
Physicists
Regional registration No. 287

The sample name and, when relevant, its description, are given by the orderer, and CATAS does not assume responsibility on this matter. This test report relates to the sample submitted for the test and no others. Additions, deletions or alterations are not permitted. This test report must always be reproduced in its entirety. Unless otherwise required by standards and technical specifications or agreed with the customer, any declarations of conformity made by CATAS are based on the comparison between results and reference values, where the confidence intervals of the measures are not taken into account. Unless otherwise stated, sampling is made by the customer; in this case the test results are referred to the sample as received.